




# Transformer



**Catalog Number** 9T10A1001 **Type QL**

**15.0 KVA 60 HZ 3 PH 3.7 % IMP**  
40 C.AMB. 150 C.RISE 220 C.SYSTEM IS-19C  
*Note: Design is based on 15.00KVA & 115C Rise 3.4% Imp.*




JUMPER CONNECTION	
TAP	VOLTS
1	504
2	493
3	480
4	468
5	455
6	445
7	432

**NET WGT**  
231 LB  
104.8 Kg  
63964  
UX71A  
NOG  
092518  
**INSPECTION & FINAL TEST N839!**

**PRIMARY (H) 480 VOLTS (LINE-LINE)**  
**SECONDARY (X) 208 VOLTS (LINE-LINE)**  
120 VOLTS (LINE-NEUTRAL)

### COIL TAP ARRANGEMENT



ENCLOSURE TYPE 2 (IP20). OR RAINPROOF TYPE 3R (IP22) WHEN PROVIDED SHIELD 9T18Y1071G06

Assembled in Mexico

BEFORE HANDLING, INSTALLING AND OPERATING, SEE INSTRUCTION 475A667AAP001 Outline:  
ALUMINUM CONDUCTOR PRIMARY: 10 KV BIL SECONDARY: 10 KV BIL 3038111GEUKP71A

**X3 H3 X2 H2 X1 H1 X0**

**IN ACCORDANCE WITH NEC SECTION 450-9, ALLOW AT LEAST SIX INCHES CLEARANCE FOR VENTILATION. CHECK ADDITIONAL NEC AND LOCAL CODE**

Note: standard

X0  
X1 H1  
X2 H2  
X3 H3



X0  
X1 H1  
X2 H2  
X3 H3



GE Energy Industrial Solutions

NEMA CLASS AA DRY TYPE TRANSFORMER

Meets DOE 2016 efficiency