



[home](#)

[products](#)

[services](#)

[markets](#)

[resources](#)

[your business](#)

[Buy Online!](#) | [My Cart](#)

Search Parameters:

[e-Catalog](#) > [Transformers](#) > [Dry Type Vented](#)

Transformers, Dry Type Vented

Product #: 9T83B3873

Short Description: AL 3P 45KVA 480-208Y/120

[Print This Page](#)

[Email This Page](#)

SPECIFICATIONS

Category	General Purpose
Phase	3
PriVoltage	480
SecVoltage	208Y/120
KVA	45.0 KVA
Coil Material	AL
TempRise	150 °C
ElecShield	N
SubType	VENTED
Frequency	60 Hz
UL	Yes
cUL	No
CE	No
TempClass	220 °C
AmbTemp	40 °C
InsulSys	IS-19C
EnergyEfficiency	NEMA TP 1
KFactor	K1
Enclosure Type	NEMA 2
Fan Cooled	No
GSA Compliance	Yes
GO Schedule	66K
List Price	\$5575



[View Larger](#)

Publications/Resources

[9T83B3873](#)

Additional Resources for General Purpose

[Application and Technical Brochures](#)

[Catalogs and Buyers Guides](#)

[Data Sheets](#)

[Drawings-Outline and Dimensional](#)

[Installation and Instruction](#)

[White Papers](#)

[Material Safety Data Sheets](#)

[2004 CSI Master Format](#)

[1995 CSI Master Format](#)

[Cross Reference](#)

[BIM Files](#)

[Buy Log :8-7](#)

GE Type QL transformers meet NEMA TP-1 efficiency standards. They are available with aluminum or copper windings and utilize a UL recognized 220°C insulation system.

- Quiet Performance
- Core and coil assemblies are mounted on rubber isolation pads to reduce noise
- Bolted coil terminations
- Single-piece front/back is easily removable for service
- NEMA 2 drip-proof enclosure is standard; weathershield kits are available for conversion to NEMA 3R outdoor configuration
- Qualified to the seismic requirements of IEEE-693-2005 and IBC-2006
- Copper or aluminum windings
- Copper ground strap
- Robust packaging with top and side protection protects against shipping damage
- Accessible mounting flanges with front/back slotted mounting holes make installation easier
- 100% factory tested for shorts and coil integrity, current and loss, voltage, impedance and noise.
- Clear, comprehensive documentation and labeling

